

East Franklin Township  
Sewage Report  
December 22, 2017-January 25, 2018  
Report by David Stewart

The cold temperatures, warm temperatures and then cold temperatures again have caused a lot of problems with Sewage Operations.

- Three pumps at the Boltz Pump Station were repaired.
- The heater in the generator at Cowansville was replaced.
- A relay at the Adrian Plant was replaced.
- Air filters in Adrian and Fox Hollow were replaced.
- A belt in Fox Hollow and a belt in Cowansville were replaced.

Responded to a one call at Cowansville.

As of today's date, only one lab sample out of two has been taken. Weather permitting, the next lab sample will be done tomorrow, January 26<sup>th</sup>. All required lab samples were and will be collected and transported to CWM. All DMR reports for the month of December 2017 were submitted to DEP.

The oil was changed in the Service Truck.

East Franklin Township  
Sewage Report  
January 26, 2018-February 22, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

At Boltz Pump Station, a heater was installed in the Control Panel for the computer.

Responded to two one calls; one at Cowansville and one at Fox Hollow.

All required lab samples for January and February were collected and transported to CWM. All DMR reports for the month of January 2017 were submitted to DEP.

East Franklin Township  
Sewage Report  
February 23, 2018-March 29, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

A new residential sewage billing customer was added in the Fox Hollow area. This brings our total number of sewage customers to 231.

The tap-in inspection was completed at the new Fox Hollow residence.

The Chapter 94 Reports for each Sewage plant were submitted to DEP.

Responded to two one calls; one at Tarrtown and one at Fox Hollow.

All required lab samples for March were collected and transported to CWM. All DMR reports for the month of February 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
March 30, 2018-May 3, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

On April 3, 2018, sludge was hauled from the Adrian Treatment Plant and the Fox Hollow Treatment Plant by Atkinson's and was taken to the Worthington Sewage Plant.

All required lab samples for April were collected and transported to CWM. All DMR reports for the month of March 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
May 4, 2018-May 31, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

Block heater for the Adrian generator burned up, ordered new heater. Responded to (2) one calls. Replaced battery at Tarrtown generator and installed new front brakes and rotors on service truck.

All required lab samples for May were collected and transported to CWM. All DMR reports for the month of May 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
June 1, 2018-June 28, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

The Grinder pump was replaced at the Adrian Treatment Plant.

Responded to two one calls; one in Cowansville and one in Fox Hollow.

Shut off Water Notices were posted on the applicable houses.

The oil was changed in the Service Truck.

All required lab samples for June were collected and transported to CWM. All DMR reports for the month of May 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
June 29, 2018-July 26, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

A real estate transfer inspection was done in Adrian.

Responded to a one call at Cowansville.

The renewal NPDES Permit for the Fox Hollow Sewage Treatment Plant was submitted to DEP on July 3, 2018.

All required lab samples for July were collected and transported to CWM. All DMR reports for the month of June 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
July 27, 2018-August 30, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

On August 13, 2018, sludge was hauled from the Fox Hollow AND Tarrtown Sewage Treatment Plants by Atkinson's and was taken to the Worthington Sewage Plant.

All required lab samples for August were collected and transported to CWM. All DMR reports for the month of July 2018 were submitted to DEP.



East Franklin Township  
Sewage Report  
August 31, 2018-September 27, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected.

A belt had to be replaced at the Tarrtown Treatment Plant.

The flow meters at all the Sewage Treatment Plants were calibrated. We will receive a certification for each plant. According to DEP, the calibrations of all flow meters are now required to be done on a yearly basis.

A real estate inspection was done in Cowansville.

All required lab samples for September were collected and transported to CWM. All DMR reports for the month of August 2018 were submitted to DEP.

East Franklin Township  
Sewage Report  
September 28, 2018-October 25, 2018  
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected.

A belt was replaced at the Adrian Treatment Plant.

At the Fox Hollow Plant, there were two occasions of plugged return lines due to the leaves.

Responded to two one calls, both at Cowansville.

Purchased a new Ph meter, which will be used at all four plants.

Shut off Water Notices were posted on the applicable houses.

All required lab samples for October were collected and transported to CWM. All DMR reports for the month of September 2018 were submitted to DEP.