

East Franklin Township
Sewage Report
January 2019
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

One real estate transfer inspection was done in Cowansville.

There was a one call in Cowansville.

On January 8, 2019, two loads of sludge were hauled from the Fox Hollow Treatment Plant by Atkinson's and were taken to the Worthington Sewage Plant.

The Final NPDES Permit for Adrian Sewage Treatment Plant was received. This permit will become effective on February 1, 2019 and will expire at midnight on January 31, 2024. CWM was notified of all modifications and changes were implemented on the monthly DMR.

Repairs were done on the Sewage Truck.

All required lab samples for January were collected and transported to CWM. All DMR reports for the month of December 2018 were submitted to DEP.

East Franklin Township
Sewage Report
February 2019
Report by David Stewart

Power outages, freezing rain and thawing, and high winds made this a difficult month for sewage operations.

There were two one calls; both in Cowansville.

Shut-Off Water Notices were posted on the applicable houses.

To save on shipping costs, we purchased all the chlorine that should be needed for the entire 2019 year.

All required lab samples for February were collected and transported to CWM. All DMR reports for the month of January 2018 were submitted to DEP.

East Franklin Township
Sewage Report
March 2019
Report by David Stewart

Maintenance was performed at all four plants.

On March 14, 2019, sludge was hauled from the Fox Hollow Treatment Plant by Atkinson's and was taken to the Worthington Sewage Plant. The Clarifying Tank, Sludge Blanket lifted and emptied into the Chlorination Tank, Polishing Tank, and DeChlorination Tank. All three tanks had to be emptied and cleaned.

The Chapter 94 Reports for all four sewage plants were submitted to DEP.

There were four one calls; three in Cowansville and one in Fox Hollow.

FYI...Upon completion of an Authorization form, direct payment entries to a sewage customer's checking account is initiated for payment of sewage bills. There is no cost to the customer.

All required lab samples for March were collected and transported to CWM. All DMR reports for the month of February 2019 were submitted to DEP.