

East Franklin Township
Sewage Report
January 2019
Report by David Stewart

All Treatment Plants and Pump Stations are working as expected. No problems to report.

One real estate transfer inspection was done in Cowansville.

There was a one call in Cowansville.

On January 8, 2019, two loads of sludge were hauled from the Fox Hollow Treatment Plant by Atkinson's and were taken to the Worthington Sewage Plant.

The Final NPDES Permit for Adrian Sewage Treatment Plant was received. This permit will become effective on February 1, 2019 and will expire at midnight on January 31, 2024. CWM was notified of all modifications and changes were implemented on the monthly DMR.

Repairs were done on the Sewage Truck.

All required lab samples for January were collected and transported to CWM. All DMR reports for the month of December 2018 were submitted to DEP.

East Franklin Township
Sewage Report
February 2019
Report by David Stewart

Power outages, freezing rain and thawing, and high winds made this a difficult month for sewage operations.

There were two one calls; both in Cowansville.

Shut-Off Water Notices were posted on the applicable houses.

To save on shipping costs, we purchased all the chlorine that should be needed for the entire 2019 year.

All required lab samples for February were collected and transported to CWM. All DMR reports for the month of January 2018 were submitted to DEP.

East Franklin Township
Sewage Report
March 2019
Report by David Stewart

Maintenance was performed at all four plants.

On March 14, 2019, sludge was hauled from the Fox Hollow Treatment Plant by Atkinson's and was taken to the Worthington Sewage Plant. The Clarifying Tank, Sludge Blanket lifted and emptied into the Chlorination Tank, Polishing Tank, and DeChlorination Tank. All three tanks had to be emptied and cleaned.

The Chapter 94 Reports for all four sewage plants were submitted to DEP.

There were four one calls; three in Cowansville and one in Fox Hollow.

FYI...Upon completion of an Authorization form, direct payment entries to a sewage customer's checking account is initiated for payment of sewage bills. There is no cost to the customer.

All required lab samples for March were collected and transported to CWM. All DMR reports for the month of February 2019 were submitted to DEP.

East Franklin Township
Sewage Report
April 2019
Report by David Stewart

One real estate transfer inspection was done in Cowansville.

There were a total of two one calls.

The Final NPDES Permit for the Fox Hollow Sewage Treatment Plant was received. This permit will become effective on May 1, 2019 and will expire at midnight on April 30, 2024. CWM was notified of all modifications and changes were implemented on the monthly DMR.

All required lab samples for April were collected and transported to CWM. All DMR reports for the month of March 2019 were submitted to DEP.

East Franklin Township
Sewage Report
May 2019
Report by David Stewart

Two real estate transfer inspections were done this month; one in Adrian and one in Cowansville.

There were a total of two one calls; one in Cowansville and one in Tarrtown.

All required lab samples for May were collected and transported to CWM. All DMR reports for the month of April 2019 were submitted to DEP.

East Franklin Township
Sewage Report
June 2019
Report by David Stewart

All Treatment Plants and Pump Stations are running as expected, considering the amount of rain we have had this month. It has been difficult to keep all of the numbers in line.

On June 7, 2019, sludge was hauled from the Tarrtown Plant by Atkinson's and was taken to the Worthington Sewage Plant.

Responded to a one call this month.

All required lab samples for June were collected and transported to CWM. All DMR reports for the month of May 2019 were submitted to DEP.

East Franklin Township
Sewage Report
July 2019
Report by David Stewart

Adrian Plant: A broken flow meter was repaired.

Boltz Pump Station: There was a high level alert.

Cowansville Plant: On July 19, 2019, I had an emergency call out.

Belts and blowers were checked at all Plants.

One real estate transfer inspection was done in Tarrtown.

All required lab samples for July were collected and transported to CWM. All DMR reports for the month of June 2019 were submitted to DEP.

East Franklin Township
Sewage Report
August 2019
Report by David Stewart

Two belts were replaced at the Adrian Plant.

One real estate transfer inspection was done in Adrian.

Two one calls were done; both were in Cowansville.

There was one emergency call out at Boltz Pump Station.

Delinquent notices were posted on the applicable houses.

The Service Truck was in the garage for four days because of a recall on the transmission.

All required lab samples for August were collected and transported to CWM. All DMR reports for the month of July 2019 and all yearly reports for 2019 were submitted to DEP.

East Franklin Township
Sewage Report
September 2019
Report by David Stewart

The flow meters at all four Sewage Treatment Plants were calibrated. We received a certification for each plant. DEP requires that all flow meters be calibrated on a yearly basis.

The Sewage Department's Emergency Response Plan was reviewed and updated.

Two real estate transfer inspections were done; one in Cowansville and one in Tarrtown.

There was a one-call at Cowansville.

On September 11, 2019, three loads of sludge were hauled from the Adrian Plant and two loads of sludge were hauled from the Cowansville Plant by Atkinson's and taken to the Worthington Sewage Plant.

I attended a PA Rural Water class on September 19, 2019. This class was entitled "Risk Communication" and it was held at the Ford Cliff VFD. This class enabled me to obtain 7 Wastewater Training Credit hours.

All required lab samples for September were collected and transported to CWM. All DMR reports for the month of August 2019 were submitted to DEP.

East Franklin Township
Sewage Report
October 2019
Report by David Stewart

There were many occasions of plugged return lines due to the leaves. This is typical for this time of year.

Had three Emergency call-outs; one at Boltz Pump Station and two at Fox Hollow.

There was a one-call at Cowansville.

One real estate transfer inspection was done in Fox Hollow.

Purchased a new probe for the Ph Meter.

Delinquent notices were posted on the applicable houses.

All required lab samples for October were collected and transported to CWM. All DMR reports for the month of September 2019 were submitted to DEP.

East Franklin Township
Sewage Report
November 2019
Report by David Stewart

I attended an accredited 811 class for the proper procedure of locating and marking utility lines.

There were two one-calls at Cowansville.

All required lab samples for November were collected and transported to CWM. All DMR reports for the month of October 2019 were submitted to DEP.

East Franklin Township
Sewage Report
December 2019
Report by David Stewart

Three real estate transfer inspections were done in Tarrtown.

There were two one-calls at Cowansville.

Delinquent notices were posted on the applicable houses.

All required lab samples for December were collected and transported to CWM. All DMR reports for the month of November 2019 were submitted to DEP.