

East Franklin Township  
Sewage Report  
January 2021  
Report by David Stewart

On December 8, 2020, a new commercial sewage customer, Dollar General, was added in the Cowansville area.

There were two one-calls; one for Cowansville and one for Tarrtown.

All required lab samples for January were collected and transported to CWM. DMR reports for the month of December 2020 were submitted to DEP.

East Franklin Township  
Sewage Report  
February 2021  
Report by David Stewart

I attended an "Introduction to High Pressure Water Cleaning in Collection System Pipes" class on February 24<sup>th</sup> at the Ford Cliff Volunteer Fire Hall. This class enabled me to obtain three wastewater training credits. All fifteen credits have been completed for the dates July 1, 2019 through June 30, 2022.

Two real estate transfer inspections were done in Cowansville.

There were three one-calls; two for Cowansville and one for Fox Hollow.

All required lab samples for February were collected and transported to CWM. DMR reports for the month of January 2020 were submitted to DEP.

East Franklin Township  
Sewage Report  
March 2021  
Report by David Stewart

On March 22, 2021, three loads of sludge were hauled from the Fox Hollow Sewage Treatment Plant by CWM Environmental, Inc.

One real estate transfer inspection and a one-call was done in Adrian.

All required lab samples for March were collected and transported to CWM. DMR reports for the month of February 2020 were submitted to DEP.

East Franklin Township  
Sewage Report  
April 2021  
Report by David Stewart

On March 25<sup>th</sup>, the Chapter 94 Reports for all four sewage plants were submitted to DEP.

On March 29<sup>th</sup>, a new residential sewage customer was added in the Cowansville area.

On April 23<sup>rd</sup>, two loads of sludge were removed from the Adrian Sewage Treatment Plant and the sludge was hauled by CWM; and on this same date, the Boltz Pump Station was jet washed by CWM.

Two pumps were rebuilt for the Boltz Pump Station.

Two belts were replaced at the Adrian Sewage Treatment Plant.

There were three one-calls this month.

All required lab samples for April were collected and transported to CWM. DMR reports for the month of March 2020 were submitted to DEP.

East Franklin Township  
Sewage Report  
May 2021  
Report by David Stewart

The NPDES Renewal Permit for the Cowansville Sewage Treatment Plant was submitted to DEP on May 25, 2021.

One real estate transfer inspection was done in the Cowansville area.

There were four one-calls; two in Fox Hollow, one in Cowansville and one in Tarrtown.

All required lab samples for May were collected and transported to CWM. DMR reports for the month of April 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
June 2021  
Report by David Stewart

At Fox Hollow, there were high temperatures within the Blower.

There was a one-call at Tarrtown.

All required lab samples for June were collected and transported to CWM. DMR reports for the month of May 2021 were submitted to DEP:

East Franklin Township  
Sewage Report  
July 2021  
Report by David Stewart

We are currently negotiating with WHAWPCA regarding the Fox Hollow Sanitary Sewer Line Extension.

Replaced return valves at the Tarrtown Plant.

On July 12, 2021, sludge was removed from the Cowansville and Tarrtown Sewage Treatment plants by CWM Environmental, Inc.

As of July 15, 2021, we started reissuing water shutoff notices and terminating water service to our customers for unpaid sewage bills. The PUC's emergency order prohibiting utilities to terminate services has been lifted.

There were two one-calls.

All required lab samples for July were collected and transported to CWM. DMR reports for the month of June 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
August 2021  
Report by David Stewart

We now have a project timeline for the Fox Hollow Sanitary Sewer line expansion.

Repaired the flow meter at Cowansville and repaired the lift pump at Fox Hollow.

There were five one-calls and four call outs.

All required lab samples for August were collected and transported to CWM. Two additional lab samples were done at each plant, per DEP yearly requirements. DMR reports for the month of July 2021 were submitted to DEP.



East Franklin Township  
Sewage Report  
September 2021  
Report by David Stewart

Two real estate transfer inspections were done in Fox Hollow.

There were two one-calls in Tarrtown and two call outs in Cowansville.

Shut-Off Water Notices were posted on the applicable houses.

All required lab samples for September were collected and transported to CWM.  
DMR reports for the month of August 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
October 2021  
Report by David Stewart

The Sewage Department's Emergency Response Plan was reviewed and updated.

The flow meters at all four Sewage Treatment Plants were calibrated. We will receive a certification for each plant. DEP requires that all flow meters be calibrated on a yearly basis.

One real estate transfer inspection was done in Tarrtown.

There was a one-call for all of Tarrtown.

Shut-Off Water Notices were posted on the applicable houses.

All required lab samples for October were collected and transported to CWM. DMR reports for the month of September 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
November 2021  
Report by David Stewart

On October 26, 2021, two loads of sludge were hauled from the Fox Hollow Sewage Treatment Plant by CWM Environmental, Inc.

One real estate transfer inspection was done in Tarrtown.

There were two one-calls at Tarrtown.

Replaced a Belt at Adrian.

Unplugged two return lines; one at Fox Hollow and one at Tarrtown.

All required lab samples for November were collected and transported to CWM. DMR reports for the month of October 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
December 2021  
Report by David Stewart

Two real estate transfer inspections were done in Cowansville.

There was a call out at the Bowser Plan.

There were three one-calls in Tarrtown.

Shut-Off-Water Notices were posted on the applicable houses.

All required lab samples for December were collected and transported to CWM.  
DMR reports for the month of November 2021 were submitted to DEP.