

East Franklin Township  
Sewage Report  
January 2022  
Report by David Stewart

On January 3, 2022, sludge was hauled from the Cowansville STP by CWM Environmental.

The Comminutor and the Flow Meter was rebuilt at the Fox Hollow STP.

All required lab samples for January were collected and transported to CWM. DMR reports for the month of December 2021 were submitted to DEP.

East Franklin Township  
Sewage Report  
February 2022  
Report by David Stewart

Repairs are being made at the Boltz Pump Station. The repairs include a new pump, repairing the sewer line, etc.

Repairs were made to the Grinder at the Cowansville STP.

The NPDES Renewal Permit was submitted to DEP for the Tarrtown STP.

One real estate transfer inspection was done in Fox Hollow.

There was a total of three one-calls; two in Cowansville and one in Tarrtown.

Shut-Off Water Notices were posted on the applicable houses.

Lab samples were collected for the month of February and transported to CWM. DMR reports for the month of January 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
March 2022  
Report by David Stewart

On March 17<sup>th</sup>, the Chapter 94 Reports for all four sewage plants were submitted to DEP.

Yearly maintenance was performed on all plants; this includes oil changes, belt adjustments and lubed.

Lab samples were collected for the month of March and transported to CWM. DMR reports for the month of February 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
April 2022  
Report by David Stewart

Repairs to the Flow Meter at Boltz Pump Station will be completed as soon as possible.

Shut Off Water Notices were posted on the applicable houses.

Lab samples were collected for the month of April and transported to CWM. DMR reports for the month of March 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
May 2022  
Report by David Stewart

Sludge was hauled from Cowansville STP and Fox Hollow STP by CWM Environmental.

One real estate transfer inspection was done in Fox Hollow.

There was a one call in Cowansville.

Lab samples were collected for the month of May and transported to CWM. DMR reports for the month of April 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
June 2022  
Report by David Stewart

Sludge was hauled from Adrian STP and Fox Hollow STP by CWM Environmental.

One real estate transfer inspection was done in Fox Hollow.

Shut Off Water Notices were posted on the applicable houses.

Lab samples were collected for the month of June and transported to CWM. DMR reports for the month of May 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
July 2022  
Report by David Stewart

There was a total of three one-calls; two in Adrian and one in Cowansville.

Lab samples were collected for the month of July and transported to CWM. DMR reports for the month of June 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
August 2022  
Report by David Stewart

There was a one call at Fox Hollow.

Lab samples were collected for the month of August and transported to CWM. Two additional lab samples were done at each plant, per DEP yearly requirements. DMR reports for the month of July 2022 were submitted to DEP.



East Franklin Township  
Sewage Report  
September 2022  
Report by David Stewart

Four real estate transfer inspections were done; one at Adrian, two at Cowansville and one at Tarrtown.

There were two one-calls; one in Adrian and one in Cowansville.

Lab samples were collected for the month of September and transported to CWM. DMR reports for the month of August 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
October 2022  
Report by David Stewart

The Fox Hollow Sewage Line Extension Project is on schedule.

The Sewage Department's Emergency Response Plan was reviewed and updated.

The flow meters at all four Sewage Treatment Plants were calibrated. We will receive a certification for each plant. DEP requires that all flow meters be calibrated on a yearly basis.

There was a one-call in Cowansville.

Lab samples were collected for the month of October and transported to CWM. DMR reports for the month of September 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
November 2022  
Report by David Stewart

The breaker at Boltz Pump Station was replaced after the long wait for the part.

There was a one-call in Cowansville.

Lab samples were collected for the month of November and transported to CWM.  
DMR reports for the month of October 2022 were submitted to DEP.

East Franklin Township  
Sewage Report  
December 2022  
Report by David Stewart

Shut Off Water Notices were posted on the applicable houses.

There was a one-call in the Cowansville area.

Lab samples were collected for the month of December and transported to CWM.  
DMR reports for the month of November 2022 were submitted to DEP.